

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 19/06/2026

It is certified that an inspection team headed by Avadhesh Kumar (Chemist)

(Name of Officer with designation) from U.P. Jal Nigam (Aurai) Lab, PHED, Firozabad.

inspected the TSPS International School, Aurai (Jalesar Firozabad Road)

(Name & Address of the school) on 15/06/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. U.P.J.N./F./FZO/0060/26, dated 10/06/2026

of U.P. Jal Nigam (F.) Aurai Fzd. (PHED Lab) certified that the

TSPS International School Aurai (Jalesar Firozabad Road) (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till one year

Signature with Seal: SHIVAM RAJPUT

Name: ASSISTANT ENGINEER

Designation: DIVISION OFFICE

Name & Address of the Office: JAL NIGAM (F.) FIROZABAD

To TSPS International School
Aurai (Jalesar Firozabad Road)
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

This certificate is valid only for those parameters which are attached to the report.



Email ID :- ee_cd_ferozabad@yahoo.in

CUG Mob. :- 9473942030

कार्यालय अधिशासी अभियन्ता,
खण्ड कार्यालय,
उ०प्र० जल निगम(ग्रामीण), सुहाग नगर, फिरोजाबाद।

पत्रांक:- 11081

प्रोजे 211/म

/ 28 दिनांक 12-6-2026

सेवा में,

ई-मेल

प्रधानाचार्य

टीएसपीएस इन्टरनेशनल स्कूल

ऐरई (जलेसर-फिरोजाबाद रोड)

दूधला, फिरोजाबाद

विषय :- वाटर टेस्टिंग की जाँच के सम्बन्ध में।

महोदय,

उपरोक्त विषयक आपके पत्रांक शून्य दिनांक 15.06.2026 द्वारा उपलब्ध कराये गये 01 नम जल नमूने की जाँच कर वाटर टेस्टिंग रिपोर्ट इस खण्ड द्वारा प्रेषित की जा रही है।

संलग्नक:- उपरोक्तानुसार।

भवदीय

(देवेन्द्र कुमार सिंह)
अधिशासी अभियन्ता



District Level Water Analysis Laboratories of Uttar Pradesh
Jal Nigam (Rural) Firozabad
Lab Add- Civil line Dabarai Firozabad

Test Report Water

Water Analysis Report					
Report no.	UPJN/R/FZD/0060/26		Issue Date	18/06/2026	Page no. 01
Office Name & Address	Divisional Office, Executive Engineer, UP Jal Nigam (Rural), Firozabad				
Ref. Letter No. & Date					
Basic Details of Sample					
District	Firozabad		Block	Tundla	
Gram Panchayat	Ramgarh, Ummargarh		Village	Aurai	
Habitation	Aurai		Location	Aurai	
Water Source	Samar RO		Sample ID	FZD/0060/26	
Quantity of Sample	01 L		Date of S.C	15/06/2026	
Receiving Date	15/06/2026		S. Collector	Deeksha Sharma	
Sample Depositor	Deeksha Sharma		Analysis Completion Date	17/06/2026	
Analysis Start Date	16/06/2026				
Environmental Condition					
Temperature	26±3°C		Relative Humidity	50±15%	
Technical Data of Analysis					
S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500 :2012		Ref. Method of Analysis
			Acceptable Limit	Permissible	
1.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 08) 2017
2.	Turbidity (NTU)	1.629	1	6	IS 3025 (Part-10) 2017
3.	PH	8.1	6.5	8.5	IS 3025 (Part-11) 2017
4.	TDS (mg/L)	187.5	500	2000	IS 3025 (Part-16) 2017
5.	Alkalinity (mg/L)	278	200	600	IS 3025 (Part-23) 2019
6.	Total Hardness (mg/L)	215	200	600	IS 3025 (Part-21) 2019
7.	Sulphate (mg/L)	8.86	200	400	APHA Method 23 rd Edition -4500-SO ₄ Method E (Turbidimetric Method) 2017
8.	Nitrate (mg/L)	1.43	45	No Relaxation	APHA Method 23 rd Edition -4500-NO ₃ Method B (UV Screening Method) 2017
9.	Iron (mg/L)	0.10	1.0	No Relaxation	APHA Method 23 rd Edition -3500-Fe Method B (Phenanthroline Method) 2017
10.	Chloride (mg/L)	145	250	1000	IS 3025 (Part-32) 2019
11.	Calcium (mg/L)	29	75	200	IS 3025 (Part-40) 2019
12.	Magnesium (mg/L)	36	30	100	IS 3025 (Part-46) 2019
#BOD - Below Detection Limit, N/A- Not Analyzed					
...Parameter(s) above permissible limit are in bold digits					
Note 1- This Certificate refers only to the particular sample(s) submitted for testing					
2- This Certificate shall not produced, except in full, unless written permission for the publication or an approved abstract has been obtained from Head of Laboratory					
3- The test result reported in this certificate are valid at the time of and under the stated conditions of measurements					
4- Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of test report					
5- Parameters above permissible limit are written in Bold.					
Prepared by Chemist		Reviewed by			

END OF TEST REPORT

